

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated: 16/07/2025

No. 798

It is certified that an inspection team headed by Poavren Kumar (T.E)

(Name of Officers with designation) from P.H.E.D. Siwan

(Name of Department/ Office) inspected the New Iqra Public School, Harihans,

(Name & Address of the school) on 16/07/25 (date of inspection), checked the water test report

submitted by the school and found that the school has potable drinking water for students and staff of the

institution and is having provision for running water in the toilets and maintaining hygienic sanitation

condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 01 year

Signature with Seal: Sud
16/07/25

Name : Assistant Engineer

Designation : P.H. Sub-Division, Siwan

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :

To

New Iqra Public School

Harihans, Siwan.

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Government of Bihar
Public Health Engineering Department

District Level Water Testing Laboratory:- Siwan

Sample Collected by School Authority:- New Iqra Public School, Harihans

Date:- 11.07.2025

SL. No.	Block	Panchyat	Village	Name of Habitation	Location of Source	Parameters														
						pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	As	Total Coli
1	Hussanganj	Harihans	Harihans Purvi	Harihans Purvi	New Iqra Public School, Harihans	7.21	1	-	390	180	45	-	60	180	0.32	BDL	BDL	0.2		<1.1
Desirable Limits						6.5-	5.0	-	500	200	75	30	250	200	1.0	45	200	1.0	0.01	
Permissible Limits						8.5	NR	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	

All parameters are under desirable limits

12.07.25

Chemist D.L.L.
P.H. Division, Siwan